

Edwards - I-70 MM 160.00
Elevation \approx 7200'

CDOT Region #3



Summary Observations

An on-site ADA survey was conducted September 28, 2016, by Patrick Going, ADA Consultant. All observations are based on the *2010 ADA Standards for Accessible Design*. These Standards may be found at www.access-board.gov.

This is a modern, well-maintained rest area with easy access off I-70. This rest area is very accessible for people with disabilities though a few minor adjustments are needed; e.g. add 'van' parking sign to one post, wrap sink pipes, add restroom signs on wall.

Parking

There are 48 parking spaces with three (3) designated accessible parking spaces. There is a requirement that 1:6, but no less than one, of the accessible spaces be a 'van' space (§208.2.4). The two accessible parking spaces on northeast side need one access aisle, 8' wide, between them. Add 'van' sign to one post.

There is a separate parking area for RV's and trucks. A curb cut is needed in sidewalk for access to the building.

Path-of-Travel

The route from the current accessible parking spaces to the building are ADA compliant.

Rest Rooms

In general, the men's, women's, and family restrooms are ADA compliant with the exception the sink pipes need wrapping and signs need to be added to the wall - adjacent to the latch side of doors.

Vending Machines and Visitor Information

There is ample circulation space to reach the vending machines and visitor information.

Dog Relief Areas

There are numerous designated 'dog relief' areas. Most are accessible for people with assistive mobility devices.



ADA Graded Summary*

*Based on 2010 ADA Standards for Accessible Design



Excellent



Moderate



Poor

Parking	Path-of-Travel to Building/Services	Restrooms	Vending/Picnic Tables
			
48 spaces/3 accessible. Create access aisle between 2 current spaces. Add 'van' on 1 post.	Paved surface, curb cuts, OK slope	Women's, Men's, Family - add signs with raised letters & Braille on wall, latch side.	Vending - good Picnic tables - good Pet area - good

Recommendations	
Description	Priority
Create 8' access aisle between the the 2 accessible parking spaces in northeast area.	Immediate
Add restrooms signs, raised letters and Braille, on wall, latch side of door at men's, women's, and family restrooms.	Immediate
Create a curb cut in sidewalk for an accessible path from truck/ RV parking area.	Soon









