

**Virginia Dale Rest Area - US 287 MM 383.5**  
**Elevation  $\approx$  7034'**

**CDOT Region #4**



## Summary Observations

An on-site ADA survey was conducted August 31, 2016, by Patrick Going, ADA Consultant. All observations are based on the *2010 ADA Standards for Accessible Design*. These Standards may be found at [www.access-board.gov](http://www.access-board.gov).

This rest area provides basic restrooms, picnic tables, pet areas, and off-the-road parking.

## Parking

There are **16 total parking spaces** with two accessible parking spaces for automobiles which meets the minimum ADA scoping requirements (1:25). There is a requirement that 1:6, but no less than one, of the accessible spaces be a 'van' space. There is space for a 8' wide access aisle at the accessible parking space that would accommodate the 'van' designation.

## Path-of-Travel

The route from the accessible car and truck parking spaces to the restrooms is acceptable.

## Rest Rooms

The men's and women's restrooms have adequate maneuvering space. These are 'pit' toilets with adequate grab bars. There is running water for the sinks but not the toilets.

## Vending Machines and Visitor Information

There are no vending machines. The visitor information sign is not on an accessible path.

## Dog Relief Areas

There are numerous designated 'dog relief' areas. Most are accessible for people with assistive mobility devices.



## Graded Summary\*

\*Based on 2010 Standards for Accessible Design







Excellent



Moderate



Poor


Parking	Path-of-Travel to Building/Services	Restrooms	Vending/Picnic Tables
			
16 spaces/2 accessible. Need vertical signs and 'van' on one of the signs.	Paved surface, curb cuts, accessible slope	<b>Women's &amp; Men's-</b> Pit toilet. Exterior door heavy but manageable. Water at sink. Wrap sink pipes.	Pet area available. No Vending Machines. Picnic tables accessible. Visitor information not accessible.

Recommendations	
Description	Priority
If it is practical due to wind and environment, reduce door pressures at the two exterior restroom doors for easier opening	Immediate
Add vertical signs at head of accessible parking spaces	Immediate
Add 'van' to one of the vertical signs	Immediate
Wrap sink pipes	Immediate









**Access to picnic tables**

# VIRGINIA DALE COUNTRY

