


Wiggins - I-76 MM 66
Elevation \approx 4500'

CDOT Region #4



Summary Observations

An on-site ADA survey was conducted September 17, 2016, by Patrick Going, ADA Consultant. All observations are based on the *2010 ADA Standards for Accessible Design*. These Standards may be found at www.access-board.gov.

This is one of the nicer and well-maintained CDOT rest areas. It is easy access off I-76. This rest area is very accessible for people with disabilities though a few minor adjustments are needed; e.g. add 'van' parking sign to one post, wrap sink pipes, add restroom signs on wall).

Parking

There are 28 parking spaces with three (3) designated accessible parking spaces, but no 'van' space. There is a requirement that 1:6, but no less than one, of the accessible spaces be a 'van' space (§208.2.4).

There is a separate parking area for 28 RV's and trucks and an addition area just for 6 RVs. A curb cut from the dedicated RV area is needed for easier access to the building.

Path-of-Travel

The route from the current accessible parking spaces to the building is ADA compliant.

Rest Rooms

The men's, women's, and family restrooms are ADA compliant.

Vending Machines and Visitor Information

There is ample circulation space to reach the vending machines and visitor information.

Dog Relief Areas

There are numerous designated 'dog relief' areas. There is also a fenced in 'dog run.'



ADA Graded Summary*

*Based on 2010 ADA Standards for Accessible Design



Excellent



Moderate




Poor

Parking	Path-of-Travel to Building/Services	Restrooms	Vending/Picnic Tables
			
Auto - 28 spaces/3 accessible. No 8' access aisle available for 'van' space. Truck & RV parking accessible..	Paved surface, curb cuts, slopes ADA compliant	Women's, Men's, Family- ADA Compliant	Vending, picnic tables, pet area accessible

Recommendations	
Description	Priority
Enlarge one access aisle to 8' for 'van' and add 'van' sign to vertical post.	Immediate
At family restrooms, add sign with raised letters and Braille on wall on latch side of door.	Immediate
Create an accessible path to building from RV/Truck parking	Soon












Good 'family' restrooms



Recessed pipes good